

## Detention Pond Inspection Checklist

Oconee County Public Works  
Storm Water Management

Inspection Form Number:

DATE: 4-10-19

INSPECTED BY: Amy Morrison

LOCATION / ID#: 316 Professional Quarter

OWNER'S NAME: 316 Professional Quarter

ITEMS INSPECTED	Acceptable	Needs Immediate Correction	Emerging Problem	Comments	Date Corrected
Grass maintained & mowed	✓				
Area free of trash & debris	✓				
Embankment free of woody vegetation	✓				
Condition of dam	✓				
Condition of emergency spillway	✓				
Erosion or sedimentation around basin	✓				
Up & downstream channel conditions	✓				
Obstruction of inlet or outlet devices	✓				
Storage capacity affected by sedimentation	✓				
Condition of inlet & outlet pipes	✓				

## Detention Pond Inspection Checklist

Oconee County Public Works  
Storm Water Management

Inspection Form Number:

DATE: 4-10-19

INSPECTED BY: Amy Morrison

LOCATION / ID#: Epps Bridge Centre

OWNER'S NAME: Epps Bridge Centre

ITEMS INSPECTED	Acceptable	Needs Immediate Correction	Emerging Problem	Comments	Date Corrected
Grass maintained & mowed	✓				
Area free of trash & debris	✓				
Embankment free of woody vegetation	✓				
Condition of dam	✓				
Condition of emergency spillway	✓				
Erosion or sedimentation around basin	✓				
Up & downstream channel conditions	✓				
Obstruction of inlet or outlet devices	✓				
Storage capacity affected by sedimentation	✓				
Condition of inlet & outlet pipes	✓				

## Detention Pond Inspection Checklist

Inspection Form Number:

DATE: 10-16-19

INSPECTED BY: \_\_\_\_\_

LOCATION / ID#: Veteran's Park

OWNER'S NAME: County owned

ITEMS INSPECTED	Acceptable	Needs Immediate Correction	Emerging Problem	Comments	Date Corrected
Grass maintained & mowed	✓				✓ Road Dept
Area free of trash & debris	✓				Staff to work
Embankment free of woody vegetation					w/ DVP to correct.
Condition of dam		✓		erosion	Ongoing as
Condition of emergency spillway					ef 12-31-19
Erosion or sedimentation around basin		✓		Correct erosion problem, grass, riprap	
Up & downstream channel conditions					
Obstruction of inlet or outlet devices					
Storage capacity affected by sedimentation		✓	WAK	Unknown - need to clean out vegetation	
Condition of inlet & outlet pipes	WAK	✓		inlet good - outlet needs maintenance valve open / filter screen around outlet	