

Assessment for Water Quality Impacts
Existing County-Owned Storm Water Control Facilities

Oconee County Public Works

DATE: 9-15-20

INSPECTED BY: Amy Morrison

STRUCTURE TYPE: Detention Basin

LOCATION: Bogart Sports Complex

ASSESSMENT SHOULD BE CONDUCTED WITHIN 1 HOUR OF RAIN EVENT

Visual Observations

Excessive algae growth in pond: (circle one) Yes No

Available storage for water quality treatment: (circle one) Yes No

Sedimentation around discharge pipe: (circle one) Yes No * not too bad - Road Dept work order to check

Discharge water turbidity: (circle one) None Low Medium High

Presence of floatable matter: (circle one) Yes No If yes, describe: _____

Discharge water color: clear - light brown

Discharge water odor: none

Follow-up action warranted: (circle one) Yes No

Describe recommended follow-up action (if needed):

Road Dept. will check & clean pipes + remove
Sediment at discharge as needed

Work order # 11983 completed 9-17-20 : cleaned pipes, no
retrofit needed at this time